

THREADED ACCESSORIES

CPVC STRAPS

BAND HANGERS

BEAM CLAMPS

CLEVIS HANGERS

PIPE ROLLER SUPPORTS

SPLIT RING HANGERS

PIPE CLAMPS

CENTER LOAD BEAM CLAMPS

PIPE SHIELDS, INSULATION, & SADDLES

PIPE GUIDES & SLIDES

WALL BRACKETS

PIPE SUPPORTS

STRUCTURAL ATTACHMENTS

SEISMIC BRACING

FIG. 035

Function: Function: Size: Material: Finish: Install:

SWAY BRACE BAR JOIST ADAPTER

: Sway brace adapter used to attach a PHD Manufacturing sway brace assembly to a steel bar joist or structural member of ${}^{3}/{}_{8}$ " maximum thickness. To provide a point of connection when drilling or welding is not allowed or not practical. Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions.

Braces up to 8" Pipe MAX. Attaches to 3/8" thick MAX structural members. When attaching to a structure thicker than 3/8", please see PHD Manufacturing Fig. 045.

ial: Ductile iron

Electro-galvanized


Steel bar joist manufacturer's warranty requires attachment within 6" of chord panel point. Place on structural member with the flange contacting the back of the jaw. Tighten set screws finger tight, then evenly tighten until hex heads break off. Attach PHD structural attachment to Fig. 035 with the supplied attachment bolt, ensuring that the attachment bolt head bottoms out securely. Please note that the maximum load will be limited by the PHD Manufacturing structural attachment utilized with this adapter.

Approvals: Underwriters Laboratories listed for US and Canada and Factory Mutual approved. Listed for use with NFPA fastener tables and PHD sway brace components only.

Ordering:	Specify figure number.
------------------	------------------------

UL Maximum Design Load							
Dine Cize		lbs.	kN	Wt. Each			
Pipes	Pipe Size			lbs.	kg		
8" MAX	(200)	2015	(8.96)	2.38	(1.08)		

FM Maximum Design Load							
Beam Flange Thickness	Brace Angle	X-Z		Y-Z		A-B	
	From Vertical (Degrees)	lbs.	kN	lbs.	kN	lbs.	kN
³ / ₈ ″ Max	30°-44°	1040	(4.62)	970	(4.31)	1150	(5.11)
	45°-59°	1490	(6.62)	1370	(6.09)	1660	(7.38)
	60°-74°	1800	(8.00)	2060	(9.16)	1990	(8.85)
	75°-90°	2010	(8.94)	2300	(10.23)	2220	(9.87)



PHD Manufacturing, Inc.



44018 Columbiana-Waterford Road Columbiana, Ohio 44408-9481 Phone: 800-321-2736 • 330-482-9256 Fax: 330-482-2763 Web: www.phd-mfg.com

FIG. 035 SWAY BRACE BAR JOIST ADAPTER

Pipe Braced:8" Pipe MAXFunction:Sway brace ad

Sway brace adapter used to attach a PHD Manufacturing sway brace assembly to a steel bar joist or structural member of 3/8" maximum thickness. To provide a point of connection when drilling or welding is not allowed or not practical. Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions. Approvals: Underwriters Laboratories listed for US and Canada Factory Mutual approved Listed for use with NFPA fastener tables and PHD sway brace components only Material: Ductile Iron Steel bar joist manufacturer's warranty requires attachment within 6"of chord panel point. Place on structural member with the flange contacting the back of the jaw. Installation: Tighten set screws finger tight, then evenly tighten until hex heads break off. Attach PHD structural attachment to Fig. 035 with the supplied attachment bolt, ensuring that the attachment bolt head bottoms out securely. Please note that the maximum load will be limited by the PHD Manufacturing structural attachment utilized with this adapter.

		Din - Ci			lbs.					
		Pipe Size								
		8" MAX			2015					
	FM Maximum Design Load									
	Brace	e Angle	X-Z	Y-Z		Brace Angle	A-B			
Beam Flange	From	Vertical			Beam Flange	From Vertical				
Thickness	(De	grees)	lbs.	lbs.	Thickness	(Degrees)	lbs.			
	309	°-44°	1040	970		30°-44°	1150			
2/92 \	45	°-59°	1490	1370	2/92 14	45°-59°	1660			
3/8" Max	60°-74°		1800	2060	3/8" Max	60°-74°	1990			
	759	°-90°	2010	2300		75°-90°	2220			
$\begin{array}{c} & & & \\ & & & & \\ & & & \\ & & & \\ & & & \\ & & & & & \\ & & & & \\ & & & & \\ & & & & \\ & & & & \\ & & & & \\ & & & & \\$					a starting and a star	→^ Max.				

UL Maximum Design Load

The Complete Line of Pipe Supports and Devices

Pipe Hangers ▲ Strut & Accessories ▲ Pipe Clamps ▲ Beam Clamps ▲ Shields